

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 341

Dated: 31/03/2025

It is certified that an inspection team headed by Rajeev Kumar & Lab Staff

(Name of Officers with designation) from District Water Testing Laboratory PHED

inspected the Jindal Public School Tosham

(Name & Address of the school) on 27/03/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 341 & 347 dated 31/03/2025

of District Water Testing Laboratory (PHED Lab) certified that the  
Jindal Public School Tosham (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the  
hygienic sanitation condition in the school building & the campus as per norms prescribed by the  
Central/ State/ U.T. Govt.

This certificate is valid till 6 Months

Signature with Seal: Rajeev Kumar

Name : Rajeev Kumar

Designation : Chemist

Name & Address of the Office / Department : DWTL Bhiwani, Mehram Road,

Vidya Nayar, Bhiwani

To Jindal Public School  
Tosham

(Name & Address of the Institution)



Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Secretary  
JINDAL PUBLIC SCHOOL  
TOSHAM (BHIWANI) HR  
(Aff.No. 531117)

Seal  
PRINCIPAL  
41112-JINDAL PUBLIC SCHOOL  
TOSHAM (BHIWANI) HR  
(Aff to CBSE Aff. No. 531117)

Memo No:- 341

Date:- 31/03/2025

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : BHW/06012/3/2025 / Private	Sample Details	Date & Time
Sender : PRINCIPAL JINDAL PUBLIC SCHOOL TOSHAM	Collected By	ROHITASH SHARMA
Location : JINDAL PUBLIC SCHOOL TOSHAM NEAR BJLS COLLEGE TO	Collection Date	25/03/2025 at 16:16
Sample Description : Drinking Water	Received at lab	27/03/2025 at 15:37
Latitude / Longitude : 75.925055 / 28.872074	Analysis Start Date	27/03/2025
	Analysis End Date	27/03/2025
	Sample Quantity	2 ltr.

Test Result (As Per BIS 10500 :2012)					
S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.35	1 NTU	5 NTU	APHA 24th Edition -2130 B
2	Taste	Agreeable	Agreeable	Agreeable	APHA 24th Edition -2160C
3	Odour	Agreeable	Agreeable	Agreeable	APHA 24th Edition -2150B
4	Color	1	5 Hazen Units	15 Hazen Units	APHA 24th Edition -2120B
5	Total Dissolved Solids @ 180°C ± 2°C	127	500 mg/ltr.	2000 mg/ltr.	APHA 24th Edition -2540 C
6	Total Hardness as CaCO <sub>3</sub>	55	200 mg/ltr.	600 mg/ltr.	APHA 24th Edition -2340 C
7	Calcium as Ca	14.02	75 mg/ltr.	200 mg/ltr.	APHA 24th Edition -3500-Ca B
8	Magnesium as Mg	4.86	30 mg/ltr.	100 mg/ltr.	APHA 24th Edition -3500 Mg B
9	Total Alkalinity	85	200 mg/ltr.	600 mg/ltr.	APHA 24th Edition -2320 B
10	Chloride as Cl	35.45	250 mg/ltr.	1000 mg/ltr.	APHA 24th Edition -4500 Cl-B
11	Sulphate as SO <sub>4</sub>	25	200 mg/ltr.	400 mg/ltr.	USEPA / APHA 24th -4500 SO <sub>4</sub> -E
12	Fluoride as F	0.27	1.0 mg/ltr.	1.5 mg/ltr.	APHA 24th Edition -4500F C/
13	Iron as Fe	0.02	1.0 mg/ltr.	1.0 mg/ltr.	USEPA
14	Nitrate as NO <sub>3</sub>	2.3	45 mg/ltr.	45 mg/ltr.	APHA 24th Edition -4500 NO <sub>3</sub> D
15	pH @ 25°C	8.19	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

Remarks :-

- \* The Results Given above are related to the sample as received and tested in PHED BHIWANI Lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.
- \* The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by :

RAJEEV KUMAR, CHEMIST  
DISTRICT WATER TESTING LABORATORY, BHIWANI  
email:-chemist.bhiwani@phedharyana.gov.in

Principal  
JINDAL PUBLIC SCHOOL  
TOSHAM (BHIWANI) HR  
(Aff.No. 531117)

Principal  
JINDAL PUBLIC SCHOOL  
TOSHAM (BHIWANI) HR  
(Aff to CBSE Aff. No. 531117)



**Subject : Bacteriological Examination Report of Water Samples**

Circle Bhiwani Circle

Division Tosham PHED

Sub Division Tosham PHESD

S.No.	Tested Parameter *	Result (MPN) **	Protocol Used	Potable / Not Potable
<b>Memo No :- 347, Date :- 31/03/2025</b>				
1	<b>Sample ID:-BHW/06011/3/2025 /Sender : PRINCIPAL JINDAL PUBLIC SCHOOL TOSHAM ,Location : , NEAR BLJS COLLEGE TOSHAM, Analysis Start/End Date: 27/03/2025 / 29/03/2025, GPS Coordinates: 75.923687 /28.871529</b>			
	Total Coliform per 100 ml	00	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023	Potable
<b>Abstract Report of Bacteriological Examination Report of Water Sample</b>				
<b>Total Sample</b>		<b>Potable</b>	<b>Not Potable</b>	
1		1	0	


\* Requirement (Acceptable Limit) : Shall not be detectable in any 100 ml sample


\*\* MPN (Most Probable Number) Per 100 ML.


**Remarks :-**

- \* The Results Given above are related to the sample as received and tested in BHIWANI lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.

Sample analyzed by :

  
RAJEEV KUMAR, CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT  
DISTRICT WATER TESTING LABORATORY, BHIWANI  
email:-[ghemist.bhiwani@phedharyana.gov.in](mailto:ghemist.bhiwani@phedharyana.gov.in)

  
Secretary  
JINDAL PUBLIC SCHOOL  
TOSHAM (BHIWANI) HR  
(Aff.No. 531117)

  
PRINCIPAL (JINDAL PUBLIC SCHOOL)  
41112-JINDAL PUBLIC SCHOOL  
TOSHAM (BHIWANI) HR  
(Aff to CBSE Aff. No. 531117)